
**STORMWATER DRAINAGE IMPROVEMENTS PROJECT
FOR FRANCIS MARION UNIVERSITY (H18-N079-MJ) (EDA#04-01-07484.01)**
CLARIFICATION

1. There are several areas along the project corridor where there is a proposed manhole adjacent to a proposed catch basin. For example, structures MH-4512 and CB-4511. For purposes of bidding the contractor shall bid these as separate structures connected by a pipe section with an equivalent diameter equal to the most downstream pipe size or engineer approved alternate which does not increase project costs.